

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4485-1433:101 Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: Firestop Systems Inc., 1412 Derwent Way, Annacis Industrial Park, Delta, B.C. Canada V3M 6H9
Contact: *Norm Johnston (604) 515-1788 Fax (604) 515-1783

DESIGN: Model 4800 liquid ceramic fiber firestop sealant. This material is packaged in color coded 30 fluid ounces cartridge, 1 and 3.17 US gallon pails. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and WHI label.

APPROVAL: Listed as through penetration fire stop systems up to 2-hour rating for opening in wall or floor/ceiling. System approved as following: WHI Design No. FS/PHV120-02. Refer to Warnock Hersey International (WHI) Certification Listings Book for detailed system constructions.

*Rev. 05-28-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**